

Date of valid edition
2017- 01-01

No/revision:
3009-21

Date of first issue
2006-02-09

Reference
2017.2 - Hallingplast

Name and address of certificate holder

Hallingplast AS
N-3570 ÅL

Conformity marks covered by the certificate



Marks regarding products in contact with drinking water



Information regarding the certificate holder/manufacturer

Contact person Rolf Dahle	Telephone +47 32 09 55 99	Telefax +47 32 09 55 94
	E-mail post@hallingplast.no	
Manufacturer Hallingplast AS	Place of manufacture Ål. Norway	

Product covered by the certificate

Type of product Plastics piping systems for water supply, and for drainage and sewerage under pressure - Polyethylene (PE)	Standard Normative document EN 12201:2011	Specific rules INSTA SBC EN 12201
<p>Specification of product</p> <p>PE 80 SDR classes: 11, 17 and 26 Nominal outside diameter: $16 \leq d_n < 710$ mm, Size groups: 1, 2 and 3</p> <p>PE 100 SDR classes: 7,4, 9, 11, 13,6, 17, 21 and 26 Nominal outside diameter: $16 \leq d_n < 710$ mm, Size groups: 1, 2 and 3 SDR classes: 11, 13,6, 17, 21 and 26 Nominal outside diameter: ≥ 710 mm, Size group: 4</p> <p>The pipes are black. The pipes may have coloured stripes. Pipes for human consumption have blue stripes. Rev. Confidential information according to enclosure. The enclosure consists of two pages.</p>		

The certificate holder above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certificate is valid on the condition that the certificate holder complies with "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The certificate holder is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the certificate holder. This also applies to defective or faulty products.

Unless terminated, the certificate will be automatically extended for one year at a time. The certificate will be re-issued with a new "date of valid edition" only if the content and/or conditions of the certificate have been changed. Termination may take place to the end of a year subject to three months notice on the part of the certificate holder and the certification body. The certificate is not transferable.

MEMBER OF INSTA-CERT
Norner AS

Dag Roar Hegna

Dag Roar Hegna